



## NSW RURAL FIRE SERVICE



Department of Planning & Environment  
Industry Assessments  
Planning Services Division  
320 Pitt Street  
SYDNEY NSW 2000

Your reference:  
Our reference: D17/4000 - AJ

11 October 2018

**Attention:** Sally Munk – [sally.munk@planning.nsw.gov.au](mailto:sally.munk@planning.nsw.gov.au)

Dear Madam,

**Macarthur Memorial Park – St Andrews Road Varroville**

Reference is made to your email dated 25 September 2018 requesting comment from NSW RFS on the internal road widths proposed for Macarthur Memorial Park.

Recommended conditions issued by NSW RFS on 5 December 2017 included:

*Internal roads shall comply with Section 4.2.7 of 'Planning for Bush Fire Protection 2006' except where modified in Section 3.4 Access for fire fighting operations of the submitted bush fire report prepared by Travers Bushfire and Ecology (Dated October 2017, Reference A16228B).*

A performance based alternate solution was assessed and supported for road widths of 6.5 metres for two way roads and 3.5 metres for one way roads with 2.1 metre wide grassed parking bays. Should any modification to the already approved alternate solution for access be proposed, an amended bushfire report and plans supporting the changes will be required for further assessment by NSW RFS.

If you have any queries regarding this advice, please contact Anna Jones, Development Assessment and Planning Officer, on 1300 NSW RFS.

Yours sincerely,

Martha Dotter  
A/Team Leader Development Assessment & Planning

**Postal address**  
NSW Rural Fire Service  
Planning and Environment Services  
Locked Bag 17  
GRANVILLE NSW 2141

T 1300 NSW RFS  
F (02) 8741 5433  
E [records@rfs.nsw.gov.au](mailto:records@rfs.nsw.gov.au)  
[www.rfs.nsw.gov.au](http://www.rfs.nsw.gov.au)

