

From: Osborn Fong <[REDACTED]>
Sent: Tuesday, 6 December 2022 10:51 AM
To: Stephen Phillips
Cc: Christine Kelly; [REDACTED]; [REDACTED]
Subject: RE: RE: President Private Hospital

Hi Stephen,

All of the builder's proposed measures that you highlighted below are appropriate.
My comments
below:

- a) Re. Point 1, the acoustic blankets must be weather-resistant (e.g. rain and UV) and be installed so that the sound-absorptive side faces towards the construction site. Alternatively, for sound absorption, products such as Stratocell Whisperquiet UV (min. 100 mm thick) may also be direct-fixed onto the plywood panels on the side facing construction.
- b) Re. Point 3, assuming that the mentioned "acoustic receivers" refers to noise loggers/monitors, the best way to demonstrate noise compliance during construction is to install these loggers at the boundary of noise receivers rather than the boundary of construction site.

Would this email suffice for now? I assume further details will be confirmed in the future.

Kind regards,
Osborn